



TEST REPORT

Short circuit resistance

TEST REPORT N° 2013 11 3S 0606

This test report summary, resume the results of the tests realized by LCOE High Power Laboratory issued the 6th February 2014. LCOE is an accredited laboratory by the Spanish accreditation body (ENAC)

Product Description: EASYCONNECT steel wire mesh cable trays. Test has been carried out using 2 sections of EC60.200EZ

Test Setup: Test Object has been tested for short time withstanding (40 kA, 200mseg) and peak current test (104 kA) according to IEC 61914:2009

- Frequency: 50/60 Hz
- Ith: 40kA
- Duration: 200 mseg
- Idyn: 104 kA (2.6· Ith)

Test Results: The test object passed successfully all the tests performed.

Verified and Approved by:

Mrs Carmen Valdés, Managing Director
VALDINOX S.L.



Santander, 7th February 2014